

RESEARCH-DEVELOPMENT AND TESTING NATIONAL  
INSTITUTE FOR ELECTRICAL ENGINEERING

# ICMET CRAIOVA HIGH POWER DIVISION

## HIGH POWER LABORATORY

"Ovidiu Rarinca"

200746-CRAIOVA, Blvd. DECEBAL No. 118A, ROMANIA  
Matriculation certificate: J16/312/1999, VAT number RO387 1599  
Phone: (351) 402 427; Fax: (251) 415482; (351) 404 890;  
E-mail: [imp@icmet.ro](mailto:imp@icmet.ro)

acreditat pentru  
ÎNCERCARE



SR EN ISO/CEI 17025:2005  
CERTIFICAT DE ACREDITARE  
nr. LI 004/2010

## TEST REPORT No. 11480

**CUSTOMER:** TIMSAN Transformatör Elektrik Motorlari ve Elektrik Cihazlari Tic. San. Ltd. Şti.  
1. Organize Sanayi Bolgesi 5. Cadde Malatya -TURKEY

**MANUFACTURER:** TIMSAN Transformatör Elektrik Motorlari ve Elektrik Cihazlari Tic. San. Ltd. Şti.  
1. Organize Sanayi Bolgesi 5. Cadde Malatya -TURKEY

**TESTED PRODUCT:** 100 kVA, 33/0.4 kV Three-phase oil immersed power transformer

**REFERENCE STANDARD:** IEC 60076-5:2006 subclause 4.2

**TEST PERFORMED:** Ability to withstand the dynamic effects of short-circuit


**TEST DATE:** 16.06.2012

**TEST RESULT:** Passed the test

Test Report has 19 pages and it is edited in 4 copies from which copy 1 for laboratory and copies 2, 3 and 4 for customer.

**HEAD OF HIGH POWER DIVISION:**

0.B. Dr. Eng. George Curcanu



**HEAD OF LABORATORY:**

Eng. Constantin Iancu

**DATE OF ISSUE:** 18.10.2012

1. Results refer to test product only.
2. Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to.
3. Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.