

ex 2/4



RESEARCH-DEVELOPMENT AND TESTING NATIONAL  
INSTITUTE FOR ELECTRICAL ENGINEERING

### ICMET CRAIOVA

200746 Craiova, Bd. Decebal Nr.118A

Certificat de înmatriculare: J 16/312/1999; Cod de înregistrare fiscală RO3871599

Phone: 0351 - 404888, 0351 - 404889; Fax 0251 - 415482, 0351 - 404890;

www.icmet.ro, e-mail:market@icmet.ro

### HIGH VOLTAGE DIVISION - HVD

High Voltage Laboratory - HVL

Phone: 0351 - 402425; e-mail:lit@icmet.ro



# TEST REPORT

## No.43426 / 20.06.2012

- CUSTOMER:** TIMSAN TRANSFORMATÖR ELEKTRIK MOTORLAN  
Organize Sanayi Bölgesi, 5. Cadde Malatya, Turkey
- MANUFACTURER:** TIMSAN TRANSFORMATÖR ELEKTRIK MOTORLAN  
Organize Sanayi Bölgesi, 5. Cadde Malatya, Turkey
- TESTED PRODUCT:**  
Three phases oil power transformer type: 100 kVA; 33<sup>+1</sup><sub>-3</sub>x1.5 / 0.4 kV  
Serial no. 5455 / 2012
- REFERENCE STANDARD:** IEC 60076 - 3 / 2000
- TESTS PERFORMED: (after short circuit test)**
  - I - Lightning impulse withstand voltage test , full wave
  - II - Separate - source withstand voltage test
  - III - Induced overvoltage withstand test
- TEST DATE:** 19.06.2012
- TEST RESULTS:** The product passed the tests.
- The report contains:** 13 pages.
- The test report is edited in:** 4 copies, copy no.1 remain in laboratory and copies 2, 3 and 4 are sent to the customer.

**HEAD OF HV DIVISION**  
Eng. PĂTRU Ion

**HEAD OF HV LABORATORY**  
Eng. BADEA Ion

- WARNINGS:**
- Results refer to the tested product only.
  - Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of Division to which laboratory belongs.
  - All signatures of the present report are original ones.